

**CITY OF KEY WEST
MONTHLY ENERGY MANAGER REPORT**

Prepared By: _____

Date: _____

Baseline Energy Use for City Occupied Buildings (see attached table):

November 1-30, 2019
kWh used: 647,559
Energy Cost: \$98,689

November 1-30, 2018
kWh used: 639,042
Energy Cost: \$89,540

OMI Meter Usage

November 1-30, 2019
kWh used: 578,318
Energy cost: \$72,955

Current Vs Baseline Water Use for City Operated Meters

July 1-30, 2019
Gal used: 5.2M
Cost: \$62,864

July 1-30, 2018
Gal Used: 1.7M*
Cost: \$19,386*

*FKAA Data not taken for full 30 days

City Hall at Glynn Archer

Monthly Electrical Usage
FEB: 42,960 kWh
MAR: 43,200 kWh
APR: 40,320 kWh
MAY: 37,680 kWh
JUN: 39,120 kWh
JUL: 46,080 kWh
AUG: 54,960 kWh
SEPT: 54,240 kWh
OCT: 48,960 kWh
NOV: 49,920 kWh

Priorities

Energy Manager not present this month due to Week Long Certified Energy Manager Training in Las Vegas, Nevada.

SALT was on scene the first week of December to reprogram the Firmware of the Inverters for the Solar Panels at City hall. All inverters are up and running with only a display error on the Fourth inverter, inverter is still operating, just not displaying the output.